1.1 FIRE-ALARM CONTROL UNIT

A. The control panel shall contain a microprocessor with 10/100 Ethernet media access controller (MAC). The system shall be designed specifically for fire detection, and notification applications. The control panel shall be listed and approved for the application standard(s) as listed under the General section. Panel shall be EDWARDS model iO Series.